GOVERNMENT OF MANIPUR
FIRE SERVICE DEPARTMENT

No. **5/2/MISC/2026-FS/625** Dated **12/10/2026**

FIRE SAFETY CERTIFICATE

Certified that the **THE MADHUMANGOL MEMORIAL HIGHER SECONDARY SCHOOL** located at **YAIRIPOK ROAD, WANGKHEI IMPHAL EAST DISTRICT, MANIPUR, WANGKHEI WANGKHEIMAYUM LEIRAK, WANGKHEI BOYS' JUNIOR HIGH SCHOOL IMPHAL EAST District, Manipur** comprised of **PUCCA CONSTRUCTION** owned / occupied by **PRESIDENT, THE MADHUMANGOL MEMORIAL HIGHER SECONDARY SCHOOL** has already been issued fire safety certificate vide this office letter No **5/2/MISC/2019-FS/2085**. The premises was re-inspected by **W. RONA SINGH, SUB-OFFICER** of Manipur Fire Service on **09/10/2026** (date of inspection) in the presence of **ELANGBAM IBOTOMBA SINGH, PRINCIPAL** (name of the Principal/Manager/Secretary or his / her representative) and observed that all the fire prevention and fire safety arrangements as provided in the premises found in good working condition. Therefore, the building / premises is fit for occupancy of Class **GROUP "B" Educational building B-1.**, with effect from **12/10/2026** for a period of 1 (one) year in accordance with rule and subject to compliance of the conditions.

Conditions for validity of the Fire Safety Certificate:

1. All the fire safety arrangement provided therein shall be maintained in good working condition at all times.
2. Any loss of life and property due to non functional fire safety measures shall be at the responsibility of the management.
3. Fire fighting training and mock drill excercise shall be organize quarterly / half yearly with intimation of fire Service Department.
4. The trained fire fighting staff should be available round the clock.
5. Any deviation w.r.t. construction etc. shall be verified by the concerned building sectioning authority.
6. Water source of Fire Fighting purposes be available in the building / premises throughout the year.
7. All exits provided in the building shall be kept free from any obstruction.
8. First Aid Kits and neccessary medicines are readily available in the building / premises.
9. Fire / Emergency telephone numbers shall be displayed on the Notice Board.

LAISHRAM NABACHANDRA SINGH
Digitally signed by LAISHRAM NABACHANDRA SINGH
Date: 2026.10.12 10:40:30 +05'30'

Director Manipur Fire Service

Issued on: 12/10/2026

Principal,
The M.M. Higher Secondary School
Wangkhei, Imphal East, District

Manager/Correspondent,
The M.M. Higher Secondary School
Wangkhei, Imphal East, District